

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:02 pm

PWS ID: UTAH11012 **Name:** ESCALANTE VALLEY HOUSING
Legal Contact: ESCALANTE VALLEY HOUSING **Rating:** Approved
 ROCK TUCKER **Rating Date:** 01/21/1986
Address: 315 East Highway 56 **Activity Status:** Active
 BERYL, UT 84714
Phone Number: 435-439-5584
City Served (Area):
County: IRON COUNTY
System Type: Community **Last Inv Update:** 02/06/2008 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 09/08/2010 **Total Dsgn Cap:**
Population: 120 **Surveyor:** NAGENDRA DEV **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers	Email Address
			Office	Emergency
AC	TUCKER, ROCK		435-439-5584	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	31
			31 Total Svc Connections

Storage

Total Storage: 28,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST003	HYDROPNEUMATIC TANK	Hydropneuma				A	YES
ST001	ESCALANTE VALLEY TWIN TANK#1	Ground	14,000 GAL	Steel		A	NO
ST002	ESCALANTE VALLEY TWIN TANK #2	Ground	14,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	ESCALANTE VALLEY BOOSTER	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	ESCAL VAL WELL	Inactive	WL	8	225 GPM	225 GPM	Yes	GW	Other		
WS002	NEW WELL	Active	WL	10	450 GPM	450 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.